



NOTES:

1. CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATION AND IDENTIFICATION OF EXISTING HOUSE CONNECTION PIPE SIZE AND MATERIAL. COUPLINGS SHALL BE OF TYPE AND SIZE REQUIRED FOR PROPER INSTALLATION.
2. ALL PIPE AND FITTINGS UP TO EXISTING HOUSE CONNECTION PIPE SHALL BE CLASS 56 6" DUCTILE IRON PIPE. ALL PIPE SHALL BE DOUBLE CEMENT LINED CONFORMING TO ANSI STANDARD A21.4 WITH A BITUMINOUS SEAL COATING INSIDE AND OUT.
3. HOUSE CONNECTIONS TO BE REPLACED AS REQUIRED TO INSTALL NEW SEWER PIPE IN SAME LOCATION AS EXISTING SEWER (\pm).



William F. Cosulich Associates, P.C.
Environmental Engineers and Scientists

GREAT NECK
WATER POLLUTION CONTROL DISTRICT

TYPICAL HOUSE CONNECTION
(WITHOUT RISER)